



Recreational Educational Camp Inspection Report

Establishment Information

Facility Name FORT WILDERNESS	Facility Type Recreational/Educational Camp (RRE)
Facility ID # SYOG-7QRVVQ	Facility Telephone # 715 277-2587
Facility Address _____ _____	Licensee Address _____ _____
Licensee Name FORT WILDERNESS	

Inspection Information

Inspection Type Routine	Inspection Date June 28, 2022	Total Time Spent _____
-----------------------------------	---	---------------------------

Equipment Temperatures

Description	Temperature (Fahrenheit)
Dining hall walk-in cooler produce air	37
Coffee shop storage fridge tall maxx cold	
Adventure Outpost 3 dr. upright cooler	
Adventure Oupost 2 dr. upright cooler	
3636Lab 2 dr. upright cooler	
Office fridge arctic air	
Lab 1 dr. upright	
Adventure Outpost 3 dr cooler in storeroom	
Coffee shop short maxx cold	37
Dining hall walk-in cooler meat/dairy air	0
Dining hall walk-in freezer	

Food Temperatures

Description	Temperature (Fahrenheit)
italian beef hot hold	160
pulled turkey cold hold	38
milk cold hold	37

Warewashing Info

Machine Name	Sanitization Method	Thermo Label	PPM	Sanitizer Name	Sanitizer Type
Dishwash dining hall	chemical		50		chlorine
Redi San Spray Bottles			1130		lactic acid
dish machine at Outpost	high temp	160+ F			
Manual three comp	manual				
coffee shop	manual warewash		300		quat
3 basin sink, Adventure					
Outpost	chemical		400		quat

Manual three comp sink
snack shop
Dining hall 3-comp

OPERATOR - The violations in operating procedure or physical arrangement indicated below must be corrected by the next routine inspection or by a date specified in this report.

Observed Violations

Total # 1

OBSERVATION: The sleeping quarters in Adventure Outpost for the infirmary do not comply with fire safety requirements. There is not a carbon monoxide detector in the infirmary sleeping rooms or in the nurses quarters attached.

CORRECTIVE ACTION(S): Install carbon monoxide detectors in all sleeping areas where furl buring appliances are present. Correct By: 01-Jul-2022

CODE CITATION: ATCP 78.21 (1)

Comments:

CFPM Nathan Duley, exp 11/14/2023 ServSafe
CFPM Kaley Wied, exp 5/16/2027 Serv Safe
CFPM Janet Merkel, exp. 2022

Adventure Outpost: approx 60 campers, 20 counselor staff, 6 lifeguards
LAB: 20 campers, 7 counselor staff, 1 lifeguard

Additional information required to be provided to Health Dept:

- 1) Certifications of all medical services staff (including volunteer medical staff), and Lifeguard Staff.
- 2) These certifications should be kept in one central location (paper or electronic form) along with food staff certifications.

Ensure rescue boat at each waterfront is ready to go and provided with the required rescue equipment ANY TIME waterfront and boating activities are occuring.

It is highly recommend that camp maintain a register or written documentation of non campers/visiting persons and due to the size of camp, have a system in place for staff and campers to visually recognize visitors in camp.

Any operator aggrieved by an order of this department under this chapter may request a hearing as provided in ch.227 statute, if state licensed, or a local ordinance if licensed by an agent health department.

Person in Charge

Sanitarian



Steve Siefert



Karrin Farrenkopf
(715) 369-6223