




PRIVATE WELL CHECKLIST



Well Head

- well cap is secured and in good condition (not cracked)
- all electrical wires are sealed in conduit
- well cap is water tight with gasket seal in place
- vent through well cap has screen, is downward facing and terminates 12' from ground
- casing is in good condition, not cracked or degraded
- casing height is adequate (>12 inches after 1991, > 8 inches pre-1991, > 6 inches pre-1953)
- well is protected from contaminant sources
- do not cover well casing with landscaping

Pressure Tank and Distribution System

- pressure tank is working properly and holding pressure
- sample tap is properly located near pressure tank
- water treatment is appropriate and regularly maintained
- no cross-connections between drinkable water and sewage water
- distribution system/piping is visually maintained
- backflow prevention devices or air gaps are installed where needed (ex: outdoor spickets with hoses attached)

HOME WELL WATER SYSTEM

